






































VOLVO		STANDARD MAINTENANCE PROCEDURE				SMP N° : 0001	
STATION: 2V11		TASK SMP : WEEKLY INSPECTION OF MAIN OPERATOR PANEL		VALIDATION / STAMP		TIME (min): 38.5	
SUB-SYSTEM: AUTOMATED CELL - BODYSIDE SUB				ENG		Created: 11/29/2022	
LEDGER COMPONENTS :				MAN POWER 1		SAFETY	
MANDATORY PPE:				SPECIFIC PPE: No special PPE beyond standard for this check.		HAZARDS: Electricity	
							
STEP	ITEM	INSTRUCTION	HAZARD	SAFETY PROCEDURES	TOOL	PARAMETER	ACTION (min)
1		Lock out robot cell.		 	LOCK	UNABLE TO START CELL	1
2		Visually inspect the Main Operator Panel for any damage, wear, indentations, or other outstanding damage.			VISUAL	GOOD CONDITION	1
3		Visually inspect the Main Operator Panel's display screen for any cracks, scratches, or other damage. Replace as necessary.			VISUAL	GOOD CONDITION	5
4	1	Visually inspect the Main Operator Panel's pushbuttons for any damaged or jammed buttons, or burnt out LEDs. Replace the pushbuttons as necessary.			VISUAL	GOOD CONDITION	2
5	2	Visually inspect the Main Operator Panel's EtherNet switch for any damage, missing connections, or exposed / fraying wires. Replace the EtherNet switch as necessary.			VISUAL	GOOD CONDITION	5
6	3	Visually inspect the Main Operator Panel's Input / Output modules for any damage, loose components, missing connections, or exposed / fraying wires. Replace the input / output modules as required.			VISUAL	GOOD CONDITION	5
7	4	Visually inspect the Main Operator Panel's CPU unit for any burnt out LEDs, non functioning display screen, loose connections, exposed wires, or other outstanding damage. Replace the CPU unit as necessary.			VISUAL	GOOD CONDITION	10
8	5	Visually inspect the Main Operator Panel's power supplies for any damage, exposed wires, fraying wires, burnt out LEDs, loose components, or missing fasteners. Replace the power supply units as necessary.			VISUAL	GOOD CONDITION	5
9	6	Visually inspect the Main Operator Panel's circuit breakers for any damage, missing connections, fraying or exposed wires, or if the circuit breakers are in the OFF position. Replace the circuit breakers as necessary.			VISUAL	GOOD CONDITION	2.5
10	7	Visually inspect the Main Operator Panel's display screen for any dirt, dust, or buildup. Use a clean rag and a non-abrasive cleaning agent to remove any foreign material from the screen.			CLEAN RAG CLEANING SOLUTION	GOOD CONDITION CLEAN	2
11							
12							
13							

STATION:

TASK SMP : WEEKLY INSPECTION OF MAIN OPERATOR PANEL

SUB-SYSTEM: AUTOMATED CELL - BODYSIDE SUB




























VOLVO		STANDARD MAINTENANCE PROCEDURE					SMP N° : 0001	
STATION: 2V11		TASK SMP : WEEKLY INSPECTION OF WEISS VARIABLE FREQUENCY DRIVE PANEL			VALIDATION / STAMP		TIME (min): 26	
SUB-SYSTEM: AUTOMATED CELL - BODYSIDE SUB					ENG		Created: 11/29/2022	
LEDGER COMPONENTS :					MAN POWER 1		SAFETY	
MANDATORY PPE:			SPECIFIC PPE: No special PPE beyond standard for this check.			HAZARDS: Electricity		
								
STEP	ITEM	INSTRUCTION	HAZARD	SAFETY PROCEDURES	TOOL	PARAMETER	ACTION (min)	
1		Visually inspect Weiss Variable Frequency Drive Panel for any damage, wear, or other outstanding damage.			VISUAL	GOOD CONDITION	1	
2	1	Visually inspect Weiss Variable Frequency Drive Panel's Drive and Power Module for any damage, wear, missing or loose connections, exposed wires, or fraying wires. Replace the Drive Module or Power Module as necessary.			VISUAL	GOOD CONDITION	10	
3	2	Visually inspect the Weiss Variable Frequency Drive Panel's circuit breaker for any damage, loose connections, or if the breaker is in the tripped position. Replace the circuit breaker as necessary.			VISUAL	GOOD CONDITION	5	
4	3	Visually inspect the Weiss Variable Frequency Drive Panel's disconnect switch for loose connections, exposed or fraying wires, missing connections, and that the switch is operational. Replace disconnect switch as necessary.			VISUAL	GOOD CONDITION	5	
5	4	Visually inspect the Weiss Variable Frequency Drive Panel's power supply unit for any loose connections, missing screws, exposed or fraying wires, burnt out LEDs, or other outstanding damage. Replace the power supply unit as necessary.			VISUAL	GOOD CONDITION	5	
6								
7								
8								
9								
10								
11								
12								

STATION:

TASK SMP : WEEKLY INSPECTION OF WEISS VARIABLE FREQUENCY DRIVE PANEL

SUB-SYSTEM: AUTOMATED CELL - BODYSIDE SUB








VOLVO		STANDARD MAINTENANCE PROCEDURE				SMP N° : 0001	
STATION: 2V11		TASK SMP : WEEKLY POWER DISTRIBUTION PANEL INSPECTION			VALIDATION / STAMP		TIME (min): 34
SUB-SYSTEM: AUTOMATED CELL - BODYSIDE SUB					ENG		Created: 11/29/2022
LEDGER COMPONENTS :					MAN POWER 1		SAFETY
MANDATORY PPE:					SPECIFIC PPE: No special PPE beyond standard for this check.		
							HAZARDS: Electricity
STEP	ITEM	INSTRUCTION	HAZARD	SAFETY PROCEDURES	TOOL	PARAMETER	ACTION (min)
1	1	Visually inspect the Power Distribution Panel for any damage or wear. Ensure that the electrical connections are free of any cuts, exposed wires, or fraying. Replace as necessary.			VISUAL	GOOD CONDITION	2
2	2	Visually inspect the Power Distribution Panel's transformers for any indentations, loose connections, or other damage. Replace as necessary.			VISUAL	GOOD CONDITION	2
3	3	Inspect the Power Distribution Panel's main disconnect switch and verify that the disconnect is placed into the ON position.			VISUAL	GOOD CONDITION	2
4	4	Inspect the Power Distribution Panel's SIEMENS circuit breakers for damage or wear. Verify all components are working properly. Replace as necessary.			VISUAL	GOOD CONDITION	2
5	5	Visually inspect the Power Distribution Panel's power supply units for any damage, wear, loose or missing connections, or exposed or fraying wires. Replace the power supplies as necessary.			VISUAL	GOOD CONDITION	2
6	6	Visually inspect the Power Distribution Panel's selectivity modules for any damage, loose connections, exposed or fraying wires, or other outstanding damage. Replace as necessary.			VISUAL	GOOD CONDITION	2
7	7	Visually inspect the Power Distribution Panel's PROFINET module for any damage, exposed or fraying wires, burnt out LEDS, or other outstanding damage. Replace the PROFINET module as necessary.			VISUAL	GOOD CONDITION	5
8	8	Visually inspect the Power Distribution Panel's input modules for burnt out LEDS, if the component is loose, or if the module has any fraying or exposed wires. Replace the input module as necessary.			VISUAL	GOOD CONDITION	5
9	9	Visually inspect the Power Distribution Panel's output modules for burnt out LEDS, if the components are loose, or if the module has any fraying or exposed wires. Replace the output module as necessary.			VISUAL	GOOD CONDITION	5
10	10	Visually inspect the EtherNet switch for any damage, burnt out LEDS, loose or missing connections, or exposed or fraying wires. Replace the EtherNet switch as necessary.			VISUAL	GOOD CONDITION	5
11		Visually inspect the Power Distribution Panel for any dirt, dust, or build up. Use a clean rag and a plant approved cleaning agent to remove any build up from the panel.			CLEAN RAG CLEANING SOLUTION	GOOD CONDITION	2
12							

STATION: 2V11

TASK SMP : WEEKLY POWER DISTRIBUTION PANEL INSPECTION


SUB-SYSTEM: AUTOMATED CELL - BODYSIDE SUB



STATION: 2V11

TASK SMP : WEEKLY INSPECTION OF ANCILLARY AIR PREPARATION PANEL


SUB-SYSTEM: AUTOMATED CELL - BODYSIDE SUB



STATION: 2V11

TASK SMP : WEEKLY INSPECTION OF MAIN AIR PREPARATION PANEL


SUB-SYSTEM: AUTOMATED CELL - BODYSIDE SUB











STATION: 2V11

TASK SMP : WEEKLY INSPECTION OF MAIN WATER STAND

SUB-SYSTEM: AUTOMATED CELL - BODYSIDE SUB














VOLVO		STANDARD MAINTENANCE PROCEDURE					SMP N° : 0001	
STATION: 2V11		TASK SMP : WEEKLY INSPECTION OF EUCHNER SAFETY GATE SWITCH			VALIDATION / STAMP		TIME (min): 10	
SUB-SYSTEM: AUTOMATED CELL - BODYSIDE SUB					ENG		Created: 11/29/2022	
LEDGER COMPONENTS :					MAN POWER 1		SAFETY	
MANDATORY PPE:		SPECIFIC PPE: No special PPE beyond standard for this check.			HAZARDS: ELECTRIC			
								
STEP	ITEM	INSTRUCTION	HAZARD	SAFETY PROCEDURES	TOOL	PARAMETER	ACTION (min)	
1	1	Visually inspect the EUCHNER Safety Gate Switch for any damage such as broken pushbuttons, burnt out LEDS, or other damage. Replace the pushbuttons as necessary.			VISUAL	GOOD CONDITION	2	
2	2	Visually inspect the EUCHNER Safety Gate Switch's electrical connections for any fraying or exposed wires. Replace as necessary.			VISUAL	GOOD CONDITION	5	
3	3	Visually inspect the EUCHNER Safety Gate Switch and verify the safety gate locks correctly. Replace the EUCHNER Safety Gate Switch if the interlocking device does not work correctly.			VISUAL	GOOD CONDITION	3	
4								
5								
6								
7								
8								
9								
10								
11								
12								

STATION: 2V11

TASK SMP : WEEKLY INSPECTION OF EUCHNER SAFETY GATE SWITCH

SUB-SYSTEM: AUTOMATED CELL - BODYSIDE SUB




VOLVO		STANDARD MAINTENANCE PROCEDURE					SMP N° : 0001	
STATION: 2V11		TASK SMP : WEEKLY INSPECTION OF LIGHT SCREENS			VALIDATION / STAMP		TIME (min): 20	
SUB-SYSTEM: AUTOMATED CELL - BODYSIDE SUB					ENG		Created: 11/29/2022	
LEDGER COMPONENTS :					MAN POWER 1		SAFETY	
MANDATORY PPE:			SPECIFIC PPE: No special PPE beyond standard for this check.		HAZARDS: ELECTRIC, EYES			
								
STEP	ITEM	INSTRUCTION	HAZARD	SAFETY PROCEDURES	TOOL	PARAMETER	ACTION (min)	
1	1	Visually inspect the safety light screens and verify there are no objects blocking the protective field. Remove any objects obstructing the light screens.			VISUAL	GOOD CONDITION	2	
2	2	Visually inspect the safety light screen's electrical connections, verify there are no loose connections, exposed or fraying wires, or other damage. Replace the connections as required.			VISUAL	GOOD CONDITION	5	
3	3	Clean the light screens using a micro-fiber rag and an anti-static plastic cleaner to remove any dirt, dust, or grime from the light screens.			CLEAN RAG ANTI-STATIC CLEANER	GOOD CONDITION	3	
4	4	Inspect the light screen's LEDs and verify no LEDs are burnt out. Replace the light screen as necessary.			VISUAL	GOOD CONDITION	10	
5								
6								
7								
8								
9								
10								
11								
12								

STATION: 2V11

TASK SMP : WEEKLY INSPECTION OF LIGHT SCREENS

SUB-SYSTEM: AUTOMATED CELL - BODYSIDE SUB



VOLVO


STANDARD MAINTENANCE PROCEDURE

SMP N° : 00001

STATION: 2V11

TASK SMP : WEEKLY INSPECTION OF OPERATOR RUN BAR

SUB-SYSTEM: AUTOMATED CELL - BODYSIDE SUB



STATION: 2V11

TASK SMP : WEEKLY INSPECTION OF OPERATOR DISPLAY PANEL

SUB-SYSTEM: AUTOMATED CELL - BODYSIDE SUB

